



# Electrical Permit Application

Date: 08/01/2025

## Owner

Owner Name:	Rivian c/o SSC	Phone:	913-438-7700 x2272
Address:	7171 W 95th Street, Suite 600	Email:	eroseberry@ssc.us.com
City, State, Zip:	Overland Park, KS 66212		

## Electrical Contractor

Applicant Name:	TBD	Email:	TBD
Address:	TBD	State License No.:	TBD
City, State, Zip:	TBD	Expiration Date:	
Phone:	TBD		

## Project

Site Address:	5 South Main Street	Elec. Heating Sys.:	
Class:	Commercial	K.W. Load:	
Estimated cost:	200000	Serv. Entrce. Size:	2500A
Install Location:		Temp. Entrance:	No
Building Use:	Commercial EV Charging	Work Commence:	2025-09-01
# of Apartments:	N/A	Read for Inspection:	

Other work to be done: New electrical service for proposed EV charging stations

Due to continued high theft rate of copper and the high price of copper causing most developers to utilize plastic water main lines: ALL COPPER BONDING WIRE TO ANY OF THE GROUNDING ELECTRODE SYSTEM MUST BE INSTALLED WITHIN A PVC OR EMT SLEEVE FROM THE METER TRIM TO THE FIRST GROUNDING ELECTRODE. ALL SLEEVES MUST BE SECURED TO THE BUILDING STRUCTURE.

Work cannot begin until payment is rendered; application is complete; and acknowledgement that any heat pump or outside attachments are understood to meet setback rules of said property.

I do hereby certify that the information contained herein is true and correct.

Emily Roseberry

Name

08/01/2025

Date